

PERIODIC MAINTENANCE OF CONNECTORS

- Connectors do not require any special maintenance.
- It is useful to check the tightness of the bolts once in three years.
- The possibility of loosening of bolts is more in the case of connectors associated with stranded conductors and Expansion Connectors.
- If a Connector has to be dismantled from the circuit, when it is reinstalled, it is essential that Contact Grease be removed from the contact surface and be reinstalled thereafter as per Erection Instruction.

